



CONDIZIONI ATMOSFERICHE: 5D

| SCENARIO 5CB1 POOL FIRE | IRRAGGIAMENTO | | | |
|---|-------------------------------------|---------------------------|---------------------------|---------------------------|
| | Distanza (m) dal centro della pozza | | | |
| | 12,5 (kW/m ²) | 7 (kW/m ²) | 5 (kW/m ²) | 3 (kW/m ²) |
| Rottura tronchetto fondo - collasso per cause esterne del serbatoio di stoccaggio TK1 | 19 | 33 | 45 | 55 |

| | | | | | | |
|--|--|---|---|-------------|-----------|----|
| 00 | giu-19 | emesso per DVRIR | | LM | GP | LF |
| rev. | date | description | drawn | checked | approved | |
| ESTENSORE | | Tecsa S.r.l. Via Figino, 101 - 20016 Pero (Milano) ITALY Tel. +39 2 33910.484 - Fax +39 2 33910.737 PIVA: IT12396090156 tecsa@tecsasrl.it - www.tecsasrl.it | REDATTO | CONTROLLATO | APPROVATO | |
| customer |  Edison E&P S.p.A. Deposito di Fermo Zona S. Maria a Mare (FM) | |  TECNOLOGIE per la SICUREZZA e l'AMBIENTE | | | |
| COMMITTEE | Stralcio planimetrico del deposito rappresentazione grafica scenari incidentali | | | | | |
| job no. | Nome | date | format | scale | drawing | |
| COMMESSA N° | NOME DEL FILE | DATA | FORMATO | SCALA | TAVOLA | |
| 35339 | 35339-TOP5CB1-POOL.dwg | giu-2019 | A4 | 1:1.000 | 5CB1P | |
| <small>CONFIDENTIALITY NOTICE This drawing is the property only of the recipient indicated above, which is the only authorized to use it. It is strictly forbidden to disclose it to third parties or reproduced without the permission of the owner.</small> | | | | | | |